

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-1288:148 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Gamewell, 60 Pleasant Street, Ashland, MA 01721
Contact: *Ray Wood (508) 231-1400 Fax (508) 231-0900

DESIGN: Model MS-95 analog/addressable, noncoded, manual pull station. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Primary Operating Supply: 21 VDC, 1.4 mA Max.

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances. May be installed in a listed outlet box or listee's backbox.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as manual pull station for use with listee's separately listed compatible *fire alarm control units. For indoor use only.

*Rev. 06-11-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager